

# The City of Wildwood

4400 New Jersey Ave

Wildwood, New Jersey 08260

William J. Cripps  
Fire Official  
Fire Department

Phone 609-846-2030

Fax 609-522-4965

wcripps@wildwoodnj.org

Ernest Troiano III  
Chief  
Fire Department

## COOKING VENDOR GUIDELINES

**Cooking vendor permits N.J.A.C. 5:70-2.9(c)1; 1E05/1L12 Type Permit Fee \$54.00**

**This is an application processing fee and is not refundable.**

- **The following are minimum guidelines for each cooking vendor at festivals, carnivals, etc.**
- **A site plan may be required by the Fire Official prior to event.**

**FIRE EXTINGUISHER:** All cooking vendors shall supply their own fire extinguishers.

N.J.A.C. 5:70-3, 906.2; All fire extinguishers shall comply with NFPA 10/2002. All fire extinguishers shall have a valid dated inspection tag, good of one year.

N.J.A.C. 5:70-3, 904.11.5; Class K portable fire extinguishers are required for cooking with vegetable or animal oils and fats.

N.J.A.C. 5:70-3, 904.11.5.1; Class K portable fire extinguishers are required for cooking with solid fuel.

N.J.A.C. 5:70-3, 904.11.5.2; Class K portable fire extinguishers required for deep fat fryers. (See 2006 IFC-NJ for size and quantity)

**PROPANE TANK:**

N.J.A.C. 5:70-3, 3003.5.3; Propane tanks shall be secured, to prevent falling over.

N.J.A.C. 5:70-3, 3801.1; Propane tanks and equipment shall comply with NFPA 58/2004.

N.J.A.C. 5:70-3, 3803.2.1; Propane tanks shall not be taken into buildings/tents, (see 2006-1 for exceptions)

**Mobile Canteens & Cooking Trailers:**

N.J.A.C. 5:70-4.7(g) All cooking operations that produce grease laden vapors shall be equipped with a ventilating hood, duct, and automatic fire suppression system.

N.J.A.C. 5:70-3, 904.6; Dry chemical extinguishing systems shall be maintained and inspected semi-annually as per NFPA 17/2002.

N.J.A.C. 5:70-3, 904.5; Wet chemical extinguishing systems shall be maintained and inspected semi-annually as per NFPA 17A/2002.

N.J.A.C. 5:70-3, 609.2; Excessive grease and residue buildup on kitchen exhaust systems, cleaning required.

**MISCELLANEOUS:**

N.J.A.C. 5:70-3, 104.3; All appliances shall be listed and labeled and approved by the fire code official. (No homemade appliances).

N.J.A.C. 5:70-3, 2403.8.2; No vehicles shall be parked within 5 feet of tents or canopies.

N.J.A.C. 5:70-3, 2404.15.3; Suitable barricades shall be provided to maintain a distance of 5 feet between the heat producing appliance and the public.

- Propane tanks between 4 and 40 lbs shall have an Overfill Protection Device for filling in NJ.
- Propane tanks shall be hydro tested every 12 years, and not dented or badly rusted.
- Regulator shall be in good condition and the relief valve shall face away from the public areas.

# The City of Wildwood

4400 New Jersey Ave

Wildwood, New Jersey 08260

Phone 609-846-2030

Fax 609-522-4965

wcripps@wildwoodnj.org

William J. Cripps  
Fire Official  
Fire Department

Ernest Troiano III  
Chief  
Fire Department

- All plastic type protective caps shall be removed from all propane tanks before operating.
- Hoses shall not be frayed or cracked, and there shall not be any type of tape on the hose.
- Hoses shall not be covered with grease and shall not be swollen.
- Hoses shall not create a tripping hazard
- Only approved lighter fluid shall be used for charcoal grills.
- Sterno warmers may be used provided the fuel containers are properly protected from being knocked over and if the fuel containers are properly enclosed within the warmer units.

**N.J.A.C. 5:70-2.7(f); The fire official upon inspection may deny or revoke a permit at any time; this can be due to failure to meet the permit conditions, unabated fire code violations or unsafe conditions.**